

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE K		PAGE 1 OF 3 PAGES		
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 2 August 2001		4. REQUISITION/PURCHASE REQ. NO. N/A		5. PROJECT NO. (If applicable)	
6. ISSUED BY DEFENSE ENERGY SUPPORT CENTER 8725 JOHN J. KINGMAN ROAD, SUITE 4950 FT. BELVOIR, VA 22060-6222 BUYER/SYMBOL – M. NICHOLSON/DESC-APP PHONE (703) 767-9652		CODE SCO600 FAX (703) 767-8757 P.P. 8.2		7. ADMINISTERED BY (If other than Item 6) CODE			
8. NAME AND ADDRESS OF CONTRACTOR (NO., street,city,county,State,and ZIP Code)				X	9a. AMENDMENT OF SOLICITATION NO. SP0600-01-R-0074		
					9b. DATED (SEE ITEM 11) June 4, 2001		
					10a. MODIFICATION OF CONTRACT/ORDER NO.		
					10b. DATED (SEE ITEM 13)		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<p>[ X ] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended, [ X ] is not extended</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment;(b) By acknowledging receipt of this amendment on each copy of the offer submitted; or(c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. I2.05 CHANGES-FIXED PRICE (AUG 87)						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: FAR 43.01						
	OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return <u>1</u> copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
Please see the following pages.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME OF CONTRACTING OFFICER Verna L. Velez			
15B. NAME OF CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY <u>Verna L. Velez</u> (Signature of Contracting Officer)		16C. DATE SIGNED 2 August 2001	

The purpose of this amendment is to address questions proposed by prospective offerors during the Preproposal conference held on July 10, 2001 concerning the solicitation.

1. Q: Is the Weston Lake wastewater treatment plant included in this solicitation?  
A: Yes
2. Q: Are any oil/water separators included in this solicitation?  
A: No
3. Q: Will system maps, permits, nov's, I & I studies, etc, be made available at the technical library:  
A: Yes, if available.
4. Q: Will the site visit and technical library be the same date?  
A: The site visits are scheduled for August 14 – 16, 2001. There will not be physical technical library located at the installation. The government will make all of the information that would be in a technical library, available on a Compact Disk. All interested parties are advised to request a copy of the CD with their mailing address as soon as possible.
5. Q: Where is Fort Jackson Family Housing on Privatization?  
A: At this time the Fort Jackson Housing Privatization is not being considered as part of this solicitation.
6. Q: Is any part of Fort Jackson a federal enclave?  
A: This question is being researched with installation legal advisors. Response to be provided at a later date.
7. Q: Where is the technical library and what is the procedure for access to the technical library?  
A: Will be available on CD.
8. Q: Will the government retain responsibility for pre-existing environmental conditions?  
A: Yes, the government will retain responsibility for pre-existing environmental conditions.
9. Q: Will the government retain liability for system safety defects until the contractor has had sufficient time to make the required upgrades?  
A: No, the government will not retain liability for the system safety defects after it has been transferred.
10. Q: Are there baseline environmental site assessments available for review?  
A: If this information is available it will be included on the Technical Library CD.
11. Q: What are the terms of each of the existing joint use agreement contracts?  
A: Will need to follow up with contracting.

12. Q: Are the copies of all permits, processes, and procedures available for excavation, spills, etc?

A: All are included on the CD.

13. Q: Are the elevated tanks two or three million gallons?

A: There are two elevated tanks. One is in use the other is physically disconnected, but still in place. The tank in use is 2.1 million gallons. The abandoned tank is approximately 1.8 million gallons. There is an existing water reservoir (ground level approximately 1.3 million gallons) which is physically disconnected, but still in place.

14. Q: Are there any sensitive areas like Fort Leavenworth's Disciplinary Barracks?

A: Yes, there are restrictive areas such as the Ammo Storage Point, Emergency Operations Center, and others. A more comprehensive list is referenced in the A-76 folder located on the CD.

15. Q: Is Fort Jackson going to a closed base?

A: Yes, the post will impose Force Protection measures 3 August 01.